

08110 STEEL DOORS AND FRAMES

1. Exterior hollow metal doors shall be not less than 16 gauge steel. The top channel of each metal door shall be solid without pockets which collect dirt and water. All exterior doors and frames shall be galvanized.
2. Interior hollow metal doors shall be not less than 18 gauge steel.
3. Exterior door frames shall be 14 gauge, all-welded construction. Interior door frames shall be 16 gauge.
4. At fire-rated construction provide fire-rated door and frame assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction.
5. Hollow metal doors and frames shall be reinforced for hardware.