

13100 LIGHTNING PROTECTION

1. Lightning protection systems shall be provided where recommended by the Risk Assessment Guide contained in NFPA 780 - Lightning Protection Code, and Kutztown University's request.