

16050 BASIC ELECTRICAL MATERIALS AND METHODS

1. The Design Professional shall assure that NEC code required clearances are provided around all electrical equipment.
2. Provide ground conductor in all feeders and branch circuits.