

16120 CONDUCTORS AND CABLES

1. All 13.2 kV feeders shall be installed in PVC ducts encased in concrete.
2. Kutztown University has a standard on 13.2 kV cable and will provide catalog information as needed.
3. All high voltage 13.2 kV terminations shall be as manufactured by Elastimold.
4. The use of metal-clad MC type cable shall be limited.